


### Washer, Electrical Equipment Bond

# **WEEB**


**Patent Pending** 

# INSTALLATION INSTRUCTIONS For Silverback Solar Please read carefully before installing.


Wiley Electronics recommends that the sufficient details of the installation be submitted to the AHJ for approval before any work is started.



WEEB-DPF







**WEEB Bonding Jumper-8.0** 

Products are tested to UL 467, CAN/CSA-C22.2 No. 41 US/Canadian standards for safety grounding and bonding equipment




#### WEEB COMPATIBILITY


The WEEB family of products can be used to bond anodized aluminum, galvanized steel, steel and other electrically conductive metal structures. All installations shall be in accordance with NEC requirements in the USA and with CSA C22.1 in Canada. The WEEBs are for use with modules that have a maximum series fuse rating of less than 25A.

#### **Standard Top Down Clamps**

The WEEBs used for bonding the PV modules to the mounting rails are compatible with various cross-sections of module frames. The following are examples of module frames that are compatible. Notice that the WEEB teeth are positioned completely under the edge of the module frame.




The following is an example of a module frame that is incompatible with the WEEB. The module frame will not contact the flexible leg of the WEEB-DPF. If the module doesn't sit against the leg, the WEEB teeth will not sit in the proper location.




Wiley Electronics LLC. 2006-2011© - All Rights Reserved

#### **Top Down Clamps for Lipped Modules**

The following are a few variations of lipped solar modules mounted with inverted U-shaped clamps. Notice that the force which the inverted U-shaped clamp exerts is in line with the WEEB teeth.




WEEB-DPF is not compatible with high lipped modules. The WEEB teeth do not intersect with the solar module frame.




#### WEEB COMPATIBILITY

Module frames like those shown here may have a ridge or lip on the bottom edge of the frame that would prevent the WEEB teeth from fully embedding.



Shown here is an example of a lip that will prevent the WEEB teeth from properly penetrating the module frame. This type of frame is not compatible with the WEEB.




Shown here is an example of a groove that will prevent the WEEB teeth from properly penetrating the module frame. This type of frame is not compatible with the WEEB

#### Important Note:


Inspect each module frame used with a WEEB to ensure that the bottom mounting face of the frame is flat, and that there are no hinderances to embedding WEEB teeth. Do not use a module with a frame that prevents the WEEB teeth from embedding fully.

#### **WEEB-DPF on Boxed Module Frames**

Certain module frames do not have enough structural strength to withstand the force required to embed a WEEB. These frames will deform and therefore not allow sufficient penetration of the WEEB teeth. The general requirements for minimum module frame thickness of "boxed" type module frames are illustrated below.



#### SYSTEM OVERVIEW



#### Important notes


Use general purpose anti-seize compound on fastener threads when installing WEEBs.


2. The NEC section 690.43 states, "Exposed non-current carrying metal parts of module frames, equipment, and conductor enclosures shall be grounded in accordance with 250.134 or 250.136(A) regardless of voltage."

WEEBs are intended for SINGLE USE ONLY. Functionality will not be guaranteed if reused.


## **WEEB-DPF ASSEMBLY**

1





Wiley Electronics LLC. 2006-2011  $\!\!\! \bigcirc -$  All Rights Reserved




#### Important note:


To correctly install mid clamp assembly, ensure that the bolt is perpendicular to the mounting rail and both sides of the solar modules are completely positioned against the mid clamp. Refer to WEEB compatibility page for illustrations. Visually check that WEEBs are properly positioned.

Important note:

WEEBs are for SINGLE USE ONLY! Do not torque fasteners down if position of solar modules is not finalized. Only slighty tighten fasteners to keep modules in place.




#### **EVEN NUMBER OF MODULES IN ROW**



X DENOTES PLACES TO INSTALL WEEB-DPF

C X R = 4 X 1 WEEB-DPF NEEDED = C X R = 4 X 1 = 4

#### **ODD NUMBER OF MODULES IN ROW**




X DENOTES PLACES TO INSTALL WEEB-DPF

C X R = 5 X 1 WEEB-DPF NEEDED = [C+1] X R = [5+1] X 1 = 6

#### Note:

When replacing a single faulty module, also remove the adjacent module which contacts the same WEEBs as the faulty module. This will ensure that there are never ungrounded modules in the array.


#### WEEBLUG ASSEMBLY



#### Important note:


- 1. WEEB-8.0 that sits under the WEEBLug is for SINGLE USE ONLY. Ensure position is correct before tightening down.
- 2. The WEEBLug-8.0 may be used with a maximum equipment ground wire of 6 AWG.

# **GROUND CONDUCTOR ASSEMBLY**



# SILVERBACK SOLAR SPLICE KIT ASSEMBLY

The flexible WEEB Bonding Jumper can be mounted in different ways shown below.



Route WEEB Bonding Jumper as shown above if edge of solar module lands between two splice rails.